# DATASHEET - M22-CLED-W

LED element, white, front mount, cage clamp



Part no.	M22-CLED-W
Catalog No.	216569
Alternate Catalog	M22-CLED-WQ
No.	
EL-Nummer	4355772
(Norway)	

# **Delivery program**

Basic function accessories			LED elements		
Description			Cage Clamp is a registered trademark of Wago Kontakttechnik GmbH/Minden, Germany		
Connection technique			Cage Clamp		
Fixing			Front fixing		
Rated operational voltage	U <sub>e</sub>	V	12 - 30 V AC/DC, 50/60 Hz		
Rated operational current	le	mA	5 - 14		
Power consumption	P <sub>max</sub> .	W	0.26		
Lifespan to EN 60064 at $t_a = +25 \text{ °C}$	t <sub>mean</sub> (AC)	h	100000		
Degree of Protection			IP20		
			at 24 V		
Colour					
			White		
Connection to SmartWire-DT			no		
Approval					
Connection technique			Cage Clamp		
Notes					
For indicator lights, illuminated pushbutton actuators, and illuminated selector switch actuators, the following applies:					
M22R only in combination with M22-LEDR					
M22G only in combination with M22-LEDG					
M22W only in combination with M22-LEDW					
M22Y only in combination with M22-LEDW					
M22B in combination with M22-LEDW or M22-LEDB					

# **Technical data**

General		
Standards		IEC 60947-5-1
Operating torque (screw terminals)	Nm	≦ 0.8
Degree of Protection		IP20
Climatic proofing		Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
Ambient temperature		
Open	°C	-25 - +70
Storage	°C	- 40 - + 80
Mounting position		As required
Mechanical shock resistance according to IEC 60068-2-27 Shock duration 11 ms, half-sinusoidal	g	> 30
Mechanical shock resistance	g	30 Shock duration 11 ms Sinusoidal according to IEC 60068-2-27
Terminal capacities	mm <sup>2</sup>	
Solid	mm <sup>2</sup>	0.75 - 2.5
Stranded	mm <sup>2</sup>	0.5 - 2.5

Contacts			
Rated impulse withstand voltage	U <sub>imp</sub>	V AC	6000
Rated insulation voltage	Ui	V	500
Overvoltage category/pollution degree			111/3
Indoor and protected outdoor installation			
Design verification as per IEC/EN 61439			

Design verification as per IEC/EN 61439 Technical data for design verification			
Rated operational current for specified heat dissipation	I <sub>n</sub>	А	0
Heat dissipation per pole, current-dependent	P <sub>vid</sub>	w	0
Equipment heat dissipation, current-dependent		w	0
	P <sub>vid</sub>		
Static heat dissipation, non-current-dependent	P <sub>vs</sub>	W	0.45
Heat dissipation capacity	P <sub>diss</sub>	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	70
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

### **Technical data ETIM 8.0**

Low-voltage industrial components (EG000017) / Lamp holder block for control circuit devices (EC000204)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Bulb socket block for command and alarm devices (ecl@ss10.0.1-27-37-12-09 [AKF027014])

Transformer integrated		No
With integrated voltage decreasing resistor		No
With light source		Yes
With integrated diode		Yes
Lamp holder		None
Rated voltage Ue at AC 50 Hz	V	12 - 30
Rated voltage Ue at AC 60 Hz	V	12 - 30
Rated voltage Ue at DC	V	12 - 30

Voltage type for actuating	AC/DC
Lamp type	LED
Connection type auxiliary circuit	Spring clamp connection
Colour lamp	White
Type of fastening	Front fastening

# Approvals

Product Standards	IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE marking
UL File No.	E29184
UL Category Control No.	NKCR
CSA File No.	012528
CSA Class No.	3211-03
North America Certification	UL listed, CSA certified
Degree of Protection	UL/CSA Type: -

# **Dimensions**

A = 39	
Pushbutton with M22-(C)K Pushbutton with M22-(C) LED + M22-XLED	

# Additional product information (links)

#### IL04716002Z (AWA1160-1745) RMQ-Titan System

IL04716002Z (AWA1160-1745) RMQ-Titan https://es-assets.eaton.com/DOCUMENTATION/AWA\_INSTRUCTIONS/IL04716002Z2021\_07.pdf System