

| | | | | | |
|---|---|-------|---------------|------|----------------------|
| 1 | 2 | 3 | 4 | 5 | 6 |
| | | RevNo | Revision note | Date | Signature Checked |

The Solid State Relay 40A is suitable to mount on the DIN Rail Mountable Heatsink (5494)

Warning: 40A rating only possible with use of a heatsink
Max load 10A without heatsink

CAUTION when testing SSR: in normal condition, AC SSR has a leak current about 0.5~2mA, therefore, when SSR input terminals without control voltage, to measure output terminals by voltage meter, meter still displays a voltage. Correct testing method is to connect a lamp (minimal)15W, and the connect the voltage meter to the lamp.

| | |
|------------|------------------------------------|
| Units | mm |
| Tolerances | ± 0.2mm unless otherwise specified |

| | | | |
|------------------------|---------------------------|--------------------------------------------------|--------------------------------|
| Itemref | Quantity | Title/Name, designation, material, dimension etc | Article No./Reference |
| Drawn by Cas Jansen | Checked by Kevin Damen | Approved by - date 28-9-2021 | File name Date 28-9-2021 |

| | | | |
|------------------------------------------------------|--|------------------|-----------------|
| 5493 | | www.damencnc.com | |
| 5493 Solid State Relay with LED Single Phase SSR-40A | | Edition | Sheet 1 OF 1 |